

ABC DRY POWDER MAP-50%TROLLEY MOUNTED25 KG FIRE EXTINGUISHER

KANEX ABC Dry Powder MAP-50%Trolley Mounted25 kg Fire Extinguishers applicable on Class A, B, C and electrically started fire, which involves flammable Solids, liquids and gases.

Brief description: ABC Dry Powder MAP-50%Trolley Mounted Fire Extinguishers with nominal charge of 25 kg and CO2 gas cylinder of 1kg as per IS: 7285. Constructed of M.S. Sheet by MIG Welding process and brass forged discharge Valve. An effective throw of about 6.5 meters (Min. 6 m.) and discharge Min. 85%



Client :

PO No.

1.00 GENERAL DATA

1.01	Manufacturer	Kanadia Fyr Fyter Pvt Ltd
1.02	Trade Mark	"KANEX"
1.03	Standard Code	IS 16018 : 2012
1.04	Type	Trolley Mounted type
1.05	Quantity	

2.00 MATERIALS OF CONSTRUCTION

2.01	Extinguishing Medium	Mono Ammonium Phosphate 50% Powder - IS 14609
2.02	Body	M.S. Sheet of IS: 2062
2.03	Neck Ring	M.S. Pipe IS: 1239 (Part – 1)
2.04	Cap	Brass to IS: 319
2.05	Siphon Tube (Inlet/Outlet)	M.S Pipe IS:3601
2.06	CO2 gas cylinder	1kg as per IS:7285
2.07	CO2 gas	As per IS: 15222
2.08	Discharge Hose with Nozzle	PVC Braided With Aluminum alloy Nozzle (IS:617)
2.09	Trolley Wheel	Solid Rubber
2.10	Carrying handle	M.S. Pipe

3.00 GUARANTEED PERFORMANCE

3.01	Performance Requirement	Min. effective Discharge Time: Min 30Sec. (Actual : 32 Sec. approx) Bulk Range of Discharge: Min. 6 meter (Actual : 6.5 meter approx) Percentage of Discharge: Not Less than 85%
3.02	Temperature Range	-30 °C to +55 °C
3.03	Service Pressure	Not to exceed 15 kgf/cm ²
3.04	Fire Rating	20A:233B

4.00 ROUTINE TESTS

4.01	Pressure test (Pt)	35 kgf/cm ² for 30 sec
4.02	Minimum Burst Pressure test (P _b) for Body	70kgf/cm ² for 60 sec
4.03	Burst Pressure Test For Discharge Hose	Not Less than 50kgf/cm ²

5.00 DIMENSIONS

5.01	Thickness of sheet	Max. Diameter: 300±10 mm. Height: 980 mm (Approx.) Filler Opening: 75mm Made Up of 3.15 mm
5.02	Full weight of cylinder	84 kg (Approx) Phosphate Treatment Followed by Pure Polyester powder coating of body DFT Not less than 50 Micron

6.00 ANTI - CORROSIVE TREATMENT

7.00 MISCELLANEOUS

7.01	Inspection & Testing	As per approved GTP
7.02	Finish	PO Red as per IS : 5 (Shade 538)
7.03	Marking	As per IS:16018 : 2012
7.04	Approvals	BIS
7.05	Maintenance, Care and Refilling	As per IS:16018 : 2012

8.00 PACKING

Corrugated paper & Suitable Jute Bags