

MONNEX DRY POWDER (PBC UREA BASED) STORED PRESSURE 4 KG FIRE EXTINGUISHER

KANEX Monnex Dry Powder (PBC -UREA Based) Stored Pressure 4 kg Fire Extinguishers applicable on Class B, C and electrically started fires.

Brief description: Monnex Dry Powder (PBC -Urea based) Fire Extinguishers with nominal charge of 4 kg (+/-2%). Constructed of MS Sheet by MIG Welding process and brass forged discharge Valve.

Factory Tested EN rating 144B with an effective throw of about 3 meters (Min. 2 m.) and discharge about 93% (Min. 85%).



Client :

PO No.

1.00 GENERAL DATA

1.01	Manufacturer	Kanadia Fyr Fyter Pvt Ltd
1.02	Trade Mark	"KANEX"
1.03	Standard Code	IS 15683:2006
1.04	Type	Portable Stored Pressure
1.05	Quantity	

2.00 MATERIALS OF CONSTRUCTION

2.01	Extinguishing Medium	Monnex (Potassium Bi carbonate Urea based dry powder) (Confirms to IS 4308)
2.02	Body	Mild Steel Sheet having Max. of 0.25% C, 0.05% P and 0.05% S
2.03	Neck Ring	M.S. Pipe
2.04	Valve	Brass
2.05	Siphon Tube	Plastic
2.06	Pressure Gauge/indicator	As per IS 15683:2006
2.07	Wall mounting Bracket with screw	Mild steel Powder Coated
2.08	Discharge Hose with Nozzle	Rubber Braided EPDM Hose (Length:465mm) with Plastic Nozzle

3.00 GUARANTEED PERFORMANCE

3.01	Performance Requirement	Min. effective Discharge Time: 13 Sec. (Actual : 18 Sec. approx) Bulk Range of Discharge: Min. 2 meter (Actual : 3 meter approx) Percentage of Discharge: Not Less than 85 % (Actual : 93 % approx)
3.02	Temperature Range	-30 °C to +55 °C
3.03	Service Pressure	15 bar
3.04	Maximum Service Pressure	18 bar

4.00 ROUTINE TESTS

4.01	Pressure test (Pt)	35 bar (3.5 MPa)
4.02	Minimum Burst Pressure test (Pb) for Body	55 bar (5.5 MPa)
4.03	Leakage test	By applying soap solution leakage to checked
4.04	Partial discharge	The second pressure or weight shall not be less than 75% of the first after interruption of the Discharge.
4.05	Burst Pressure Test For Discharge Hose	Not Less than 35 bar (3.5 Mpa)

5.00 TYPE TESTS

As per IS 15683

6.00 DIMENSIONS

6.01	Thickness of sheet	Max. Diameter: 140±10 mm.
6.02	Full weight of cylinder	Height: 490 mm (Approx.)
		Made Up of 2.0 mm
		7 kg (Approx)
		Phosphate Treatment Followed by epoxy powder coating of body DFT Not less than 50

7.00 ANTI - CORROSIVE TREATMENT

Micron

8.00 ACCESSORIES (BRACKETS & SCREWS)

Provided

9.00 MISCELLANEOUS

9.01	Inspection & Testing	As per approved GTP
9.02	Finish	PO Red as per IS : 5 (Shade 538)
9.03	Marking	As per IS 15683:2006
9.04	Approvals	CE
9.05	Maintenance, Care and Refilling	As per IS:2190
10.00	Packing	Corrugated boxes (Outer box sizes: 210x210x630mm)